

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for the City of Adrian

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During September 2014 we did not collect all of the required number of samples for total coliforms and therefore cannot be sure of the quality of our drinking water during that time.

What should I do? There is nothing you need to do at this time. This is *NOT* an emergency. You do not need to boil water or use an alternative source of water at this time.

The table below lists the contaminants for which we did not properly test during September 2014:

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	Date next samples were taken
Total Coliform Bacteria	25 samples per month	22	09/01/2014 through 09/30/2014	10/01/2014 through 10/31/2014

What happened? What is being done?

In the month of September 2014 we were required to collect 25 routine samples from the distribution system. We collected 22 routine samples and 3 repeat samples in the month of September only to learn afterwards that the 3 repeat samples cannot count towards the 25 routine samples that are required each month. The correct number of samples was collected the following month (October 2014) and subsequent months and the City of Adrian is in compliance. Corrective measures have been put into place to prevent reoccurrence of this violation.

For more information, please contact Mr. Tim Ritchie at 517-264-4828, or the Michigan Department of Environmental Quality at 517-780-7840.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by the City of Adrian.